

Memorandum

To: James D. Boyd, Presiding Member
John L. Geesman, Associate Member

Date: April 17, 2006

From **Bill Pfanner**



Telephone (916) 654-4206

California Energy Commission
1516 Ninth Street
Sacramento CA 95814-5512

Subject: **San Francisco Electric Reliability Project (04-AFC-1):
Errata to Soil & Water Condition of Certification 13**

DOCKET	
04-AFC-1	
DATE	APR 17 2006
RECD.	APR 17 2006

Staff filed its Supplemental Testimony on Waste Management and Soil and Water-13 on April 10, 2006. The changes to the condition made by this errata reflect the underlying authority and responsibility of the San Francisco Regional Water Quality Control Board.

SOIL & WATER -13. Prior to site mobilization, the project owner shall submit to the CPM a Removal Action Work Plan or a Remedial Action Plan ("RAW" or "RAP" or the equivalent) approved by the SFRWQCB, or alternatively, either a waiver or "no action" letter from that agency. Remedial measures shall be selected to ensure that the risk to the off-site public posed by the site after remediation shall not exceed 1×10^{-6} and the Hazard Index shall not exceed 1.0, and the risk to site construction and operations workers during site activities shall not exceed 1×10^{-5} and a Hazard Index of 1.0.

Verification: At least 60 days prior to site mobilization, the project owner shall submit a copy of the above-specified documentation to the CPM.